

Evaluasi Sistem Proteksi dan Penanggulangan Bahaya Kebakaran di Rumah Sakit Haji Jakarta Tahun 2012

Setiawan, Dinar Agus

Deskripsi Lengkap: <https://lib.fkm.ui.ac.id/detail.jsp?id=90448&lokasi=lokal>

Abstrak

Kebakaran merupakan salah satu bencana yang sangat sering terjadi khususnya di daerah perkotaan padat penduduk. Rumah sakit merupakan tempat kerja yang juga rawan kebakaran. Penelitian ini membahas tentang evaluasi sistem proteksi dan penanggulangan bahaya kebakaran di Rumah Sakit Haji Jakarta. Penelitian ini adalah penelitian deskriptif kualitatif dengan menggunakan pendekatan observasional. Obyek dalam penelitian ini adalah sistem proteksi aktif dan pasif kebakaran, utilitas bangunan gedung, sarana penyelamatan diri, sarana akses pemadam kebakaran dan manajemen keselamatan kebakaran. Standar yang digunakan adalah Kepmen PU No. 10/KPTS/2000, Permen PU No. 26/PRT/M/2008, Permenaker No. : PER.04/MEN/1980, Permenaker No. : PER.02/MEN/1983, Perda DKI Jakarta No. 8 Tahun 2008, Perda DKI Jakarta No. 3 Tahun 1992. Hasil penelitian dibandingkan dengan standar peraturan. Hasil penelitian menunjukkan bahwa sistem proteksi aktif dan pasif, utilitas bangunan gedung dan manajemen keselamatan kebakaran di Rumah Sakit Haji Jakarta sepenuhnya sudah sesuai dengan standar peraturan. Sarana penyelamatan diri dan sarana akses pemadam kebakaran pada Rumah Sakit Haji Jakarta masih perlu ditingkatkan lagi.

Fire is one of the disasters that happen very often, especially in densely populated urban areas. The hospital is also prone to workplace fires. This study discusses the evaluation of protection systems and fire prevention Haji Hospital in Jakarta. This research is a qualitative descriptive study using observational approach. The object of this research is a system of active and passive fire protection, utility buildings, means of escape, fire department means of access and fire safety management. The Standar used was Kepmen PU No. 10/KPTS/2000, Permen PU No. 26/PRT/M/2008, Permenaker No. : PER.04/MEN/1980, Permenaker No. : PER.02/MEN/1983, Perda DKI Jakarta No. 8 Tahun 2008, Perda DKI Jakarta No. 3 Tahun 1992. The results compared with regulatory standards. The results showed that active and passive protection systems, utility buildings and fire safety management in Hospital Haji Jakarta is fully in accordance with the standard rules. While the means of escape and means of access to the fire department at the Hospital Haji Jakarta still needs to be improved.