

Evaluasi Sarana Pencegahan dan Penanggulangan Kebakaran di Gedung Puskesmas Kecamatan Y dan Z Tahun 2013

Rosianna S, Helga

Deskripsi Lengkap: <https://lib.fkm.ui.ac.id/detail.jsp?id=99755&lokasi=lokal>

Abstrak

Sistem proteksi kebakaran, sarana penyelamatan jiwa dan program pemeriksaan dan pemeliharaan sarana tersebut merupakan bagian dari sarana pencegahan dan penanggulangan kebakaran yang harus terdapat pada gedung bertingkat khususnya gedung yang merupakan sarana pelayanan kesehatan.

Tujuan penelitian ini adalah untuk mengetahui pemenuhan sarana pencegahan dan penanggulangan kebakaran yang ada di gedung puskesmas kecamatan Y dan Z terhadap standar. Desain penelitian yang digunakan adalah desain penelitian observasional dengan pendekatan cross sectional. Analisis yang dilakukan adalah analisis perbandingan dengan standar Keputusan Menteri Pekerjaan Umum Nomor 10 tahun 2000, Peraturan Menteri Pekerjaan Umum nomor 26 tahun 2008 dan NFPA 10, 13, 14, 25, 72 dan 101.

Hasil penelitian menunjukkan bahwa 7 elemen sistem proteksi aktif, 8 elemen sarana penyelamatan jiwa dan 7 elemen program pemeriksaan dan pemeliharaan sarana pencegahan dan penanggulangan kebakaran di puskesmas kecamatan Y tidak sesuai dengan standar. 13 elemen sistem proteksi aktif, 11 elemen sarana penyelamatan jiwa dan 7 elemen program pemeriksaan dan pemeliharaan sarana pencegahan dan penanggulangan kebakaran di puskesmas kecamatan Z juga tidak sesuai dengan standar.

Fire protection system, means of escape and inspection and maintenance program of that means is part of means of prevention and control of fire in building especially in health center building.

The purpose of this research is to know the compliance of prevention and control of fire at Puskesmas Kecamatan Y and Z building in 2013 to Indonesian and International standard. Design of this research is observational with cross sectional approach and doing comparison analysis with. Kepmen PU No.10/KPTS/2000, Permen Pu No.28/RTP/2008 and NFPA 10,13,14,25,72 and 101 standard.

The result of this research showed that 19 element of fire protection system, 8 element of means of rescue and 37 element of inspection and maintenance program in Puskesmas Kecamatan Y does not according to the standard. 13 element of fire protection system, 11 element of means of rescue and 7 element of inspection and maintenance program in Puskesmas Kecamatan Z does not according to the standard too.